

ADDENDUM NUMBER #1

<u>PROJECT</u>	<u>BIDS DUE</u>
<i>City of Clare Water Treatment Plant Upgrades Division A: Iron Removal Filter Replacement</i>	<i>Date: July 2, 2019 Time: 1:00 PM Location: City of Clare City Hall 202 W Fifth Street Clare, MI 48617</i>

The Addendum is issued prior to the receipt of bid proposals to amend the Contract Documents as follows. Bidders shall acknowledge receipt of this addendum by signed and submitting this form along with bid proposal.

SPECIFICATIONS

1. Section 11000 – Remove and Replace Section 3.4. A.2.a.2) with the following:
 - 2) Flanged 125#, CI Body, **Buna-N OR EPDM** Seat, Position Indicator, Open Left. Actuator Position 2 or 4.
2. Section 11000 – Remove and Replace Section 3.5. A.3.f with the following:
 - f. Type of Underdrain: Perforated steel plate with stainless steel baffles. Flat plate design; 3/8" plate only. **Curved plate underdrains will be considered an acceptable alternate.**

DRAWINGS

1. Sheets PM1.1 and PM1.2– Clarification: Contractor shall assume the existing wall to be removed is load bearing. The contractor shall be responsible to provide the necessary temporary and permanent supports subject to approval by the Owner. All costs to be included in the cost of the project.

This Addendum No. 1 becomes part of the Contract Documents as of this date and supersedes the information in the originally issued Contract Documents where applicable. The Contractor shall acknowledge receipt of the Addendum by signing and submitting with bid proposal. By signing the bidder understands, acknowledges and agrees to comply with this addendum.