

**ADDENDUM NUMBER #1**


Page 1 of 1

PROJECT	BIDS DUE
Ottaway Crossing Bridge and Site Work GFA Project No: 23101	Date: <b>April 1, 2025</b> Time: <b>2:00 PM</b> Location: GTCD Office 1450 Cass Road Traverse City, MI 49685

The Addendum is issued prior to the receipt of bid proposals to amend the Contract Documents as follows. **Bidders shall acknowledge receipt of this addendum by means of acknowledging on Page 1 of the Bid Form (EJCDC C-410).**

CLARIFICATIONS

1. 25A Special stone is an acceptable alternative to the Afton Stone specified in the project plans.
2. The crane pad locations and dimensions can be shifted/adjusted with the Owners and Engineers approval from where shown on the project plans. The Contractor shall submit crane access and staging plans to the Engineer for review and approval prior to the project beginning.
3. The existing two track/access road from Keystone Road to the east of the bridge crossing can be widened as necessary for machine access. This widening can remain upon project completion and the cost associated with this work shall be considered incidental and included in other bid items. Caution shall be exercised near any water or culvert crossings to protect existing infrastructure.
4. All Bidders are reminded that this project has specific restoration requirements due to the project proximity to the Boardman River. Refer to Technical Spec 02910 Restoration & Cleanup for more details.
5. Detail 3 on Sheet 8 of the plans shall be stricken in its entirety from the bid documents and replaced with the following:



This Addendum No. 1 becomes part of the Contract Documents as of this date and supersedes the information in the originally issued Contract Documents where applicable. The Contractor shall acknowledge receipt of the Addendum in the Bid Schedule included with his/her bid.