GOURDIE-FRASER
1820 Oak Hollow Drive,
Traverse City, MI 49685

Date: October 19, 2026

ADDENDUM NUMBER #2

PROJECT	BIDS DUE	
Charter Township of Garfield South Airport Road Force Main Replacement GFA Project No: 26273	Date: Time: Location:	October 22, 2026 9:00 AM Charter Township of Garfield 3848 Veterans Drive Traverse City, MI 49684

The Addendum is issued prior to the receipt of bid proposals to amend the Contract Documents as follows. Bidders shall acknowledge receipt of this addendum by including with their bid package and signing below.

CLARIFICATIONS

1. Pertinent to South Airport Road Repair – Two West Bound Lanes the following clarification is provided. This shall supersede the detail on Sheet C3.1.

   Existing limits of asphalt to be removed and replaced shall be milled to full depth, aggregate base conditioning performed should be milled full depth, perform aggregate base conditioning with compactive effort to achieve 98% of maximum dry density to reconstruct this section of the road to match existing roadway geometrics. Base and top course of asphalt shall be applied according to EMH mix in accordance with current MDOT HMA Selection Guide below. Based on the current Average Daily Traffic Volume, 5EMH top course mix design shall be provided.
   https://www.michigan.gov/mdot/-/media/Project/Websites/MDOT/Business/Local-Government/Local-Agency-Program/Design/Hot-Mix-Asphalt-Selection-Guidelines-012726.pdf

2. Pertinent to South Airport Road Repair – Two West Bound Lanes Bid Item and corresponding measurement and payment shall be corrected as follows and supersede Addendum #1:

   Bid Item No. 3- Asphalt Surface, Milling 2350 SY

   1. Asphalt Surface, Milling: The completed work for asphalt surface milling shall be paid for at the contract unit price by the square yard (SY) on the basis of the actual quantity removed as indicated on plans. This unit price shall include, but not be limited to, pavement saw cut cuts, pavement removal, offsite hauling and transportation, disposal, and all other labor, materials, and equipment necessary to complete the work according to the plans and specifications. Any damage outside of the limits defined on the drawings will be repaired/replaced at no additional cost to the project.

This Addendum No. 2 becomes part of the Contract Documents as of this date and supersedes the information in the originally issued Contract Documents where applicable. The Contractor shall acknowledge receipt of the Addendum in the Bid by signing below.

_____

Bidders Signature