

GFA  
123 West Front Street  
Traverse City, Michigan 49684

Date: November 18, 2021

### ADDENDUM NUMBER 1

| <u>PROJECT</u>                             | <u>BIDS DUE</u>  |
|--|--|
| GFA Project No: 21147<br>Chemical Feed RFP | Date: November 24, 2021<br>Time: 4:00 PM<br>Location: Email / Fax / Mail Proposal:<br>123 West Front Street<br>Traverse City MI 49684<br>231-946-3703<br>jennifer@gfa.tc |

The Addendum is issued prior to the receipt of bid proposals to amend the Contract Documents as follows. Bidders shall acknowledge receipt of this addendum by means of a handwritten note on the Bid Schedule.

[www.gfa.tc](http://www.gfa.tc)

[www.cityofclare.org](http://www.cityofclare.org)

#### GENERAL

1. THIS PROJECT IS NOT PREVAILING WAGE NOR TAX EXEMPT
2. All state permits will be obtained by the Owner. The contractor is still responsible to obtain/ coordinate the building, mechanical, plumbing, and electrical permits, inspections, and associated fees with the local regulatory agency.
3. The Owner will adhere to the nondiscrimination statement below when selecting Bidder.

*"In accordance with Federal civil rights law and U.S. Department of Agriculture (USDA) policy, this institution is prohibited from discriminating on the basis of race, color, national origin, age disability, religion, sex, familial status, sexual orientation, and reprisal.*

*To file a complaint of discrimination, write to:*

*USDA, Assistant Secretary for Civil Rights  
Office of the Assistant Secretary for Civil Rights  
1400 Independence Avenue, S.W., Stop 9410  
Washington, DC 20250-9410*



*Or call toll-free at (866) 632-9992 (English) or (800) 877-8339 (TDD) or (866) 377-8642 (English Federal-relay) or (800) 845-6136 (Spanish Federal-relay).  
USDA is an equal opportunity provider, employer, and lender."*

## SPECIFICATIONS

1. Specification 11242:
  - a. Section 2.02.A shall be removed in its' entirety and replaced in its entirety with the following:
    - A. Manufacturers
      1. Watson-Marlow, Inc.
      2. Blue - White
      3. Or Engineer Approved Equal
  - b. Section 1.03 B. 1 shall be removed in its entirety and replaced in its entirety with the following: Pump shall be 24 hr continuous duty rated and have a minimum three-year manufacturer's warranty from date of shipment.
  - c. Section 2.02 C. 1. a: The following section shall be removed and replaced with the following:
    - a. Pumps shall be positive displacement type complete with replaceable cartridge-style peristaltic pump head technology and self-contained variable speed drive as specified.
  - d. Section 2.02 C. 2. a: The following section shall be removed in its entirety. Opening the pump head for maintenance is allowed.

This Addendum No. 1 becomes part of the Contract Documents as of this date and supersedes the information in the originally issued Contract Documents where applicable. The Contractor shall acknowledge receipt of the Addendum in the Bid Schedule included with his/her bid.